

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER  
Violation for failure to complete corrective actions  
Buffalo Creek PSD Amherstdale, WV 25607

Our water system violated drinking water violation for failure to complete action in a timely matter. Even though these were not emergencies, you as our customers, have a right to know what happened and what we did to correct the situation. We are required to monitor your drinking water on a regular basis.

An on-site evaluation of our system is conducted on a regular basis. Results of the evaluation, show significant deficiencies in our water system which must be addressed to the Office of Environmental Health Services District Office. We did not correct these deficiencies by the required date and are therefore in violation.

What should I do?

There is nothing you need to do at this time.

What happened?

The storage Tank 3 has a leak. No parameters exist with detections which exceed a safe level.

What is being done?

We are having professional welders come and repair the leak at the tank.

For more information, please contact Herby Pruitt at (304)583-6586 or by mail at  
Buffalo Creek PSD  
P.O. Box 209  
Amherstdale, WV 25607

This notice is being sent to you by Buffalo Creek PSD  
State Water System ID#WV3302347

Date prepared: March 7, 2024

Date Distributed: March 13, 2024

A handwritten signature in blue ink that reads "Herby Pruitt". The signature is written in a cursive style and is positioned above a horizontal line.

Herby Pruitt, General Manager